

TEST DATE & TIME	11:20	MARCH-6-2015			TEST DATE & TIME	10:00	MARCH-11-2015		
500 ML WATER					500 ML WATER				
DIRTY AREA TESTED		CONDUCTIVITY			CLEAN AREA TESTED		CONDUCTIVITY		
		Reading	Scale			Reading	Scale		
LOCATION					LOCATION				
16 N. OF HNW-3.042		3.0	1.0		16 N. OF HNW-3.042		1.2	1.0	
17 N. OF HNW-3.043		4.8	1.0		17 N. OF HNW-3.043		1.3	1.0	
20 N. OF HNW-3.044		2.5	1.0		20 N. OF HNW-3.044		1.2	1.0	
3 N. OF HNW-0.45		3.6	1.0		3 N. OF HNW-3.045		1.3	1.0	
7 N. OF HNW-0.46		2.5	1.0		7 N. OF HNW-3.046		1.3	1.0	
13 N. OF HNW-3.047		2.0	1.0		13 N. OF HNW-3.047		1.2	1.0	
CLEAN D. I. WATER SAMPLE FROM 200 GAL. TANK		0.5	1.0				0.9	1.0	