

DOUBLE DOORS X1-7 NORTH TO SINGLE DOOR

TEST DATE & TIME	10:00	MARCH-30-2015	TEST DATE & TIME	8:00	APRIL-1-2015
500 ML WATER			500 ML WATER		
DIRTY AREA TESTED		CONDUCTIVITY	CLEAN AREA TESTED		CONDUCTIVITY
		Reading Scale			Reading Scale
LOCATION			LOCATION		
3 N. OF HNW- <u>3-072</u>	1.2	10.0	3 N. OF HNW- <u>3-072</u>	1.5	1.0
4 N. OF HNW- <u>3-073</u>	1.0	10.0	4 N. OF HNW- <u>3-073</u>	1.4	1.0
5 N. OF HNW- <u>3-074</u>	1.1	10.0	5 N. OF HNW- <u>3-074</u>	1.5	1.0
6 N. OF HNW- <u>3-075</u>	2.3	10.0	6 N. OF HNW- <u>3-075</u>	1.4	1.0
7 N. OF HNW- <u>3-076</u>	1.0	10.0	7 N. OF HNW- <u>3-076</u>	1.2	1.0
8 N. OF HNW- <u>3-077</u>	3.8	10.0	8 N. OF HNW- <u>3-077</u>	1.0	1.0
CLEAN D. I. WATER SAMPLE FROM 200 GAL. TANK	0.8	1.0		0.8	1.0