

TEST DATE & TIME	10:00	MAY-7-2015	TEST DATE & TIME	11:30	MAY-11-2015
500 ML WATER			500 ML WATER		
DIRTY AREA TESTED		CONDUCTIVITY	CLEAN AREA TESTED		CONDUCTIVITY
		Reading Scale			Reading Scale
LOCATION			LOCATION		
3 N. OF HNW-4-034		1.5 10.0	3 N. OF HNW-4-034		1.1 1.0
16 N. OF HNW-4-035		1.5 100.0	16 N. OF HNW-4-035		1.1 1.0
7 N. OF HNW-4-036		1.4 100.0	7 N. OF HNW-4-036		1.2 1.0
8 N. OF HNW-4-037		1.5 100.0	8 N. OF HNW-4-037		1.1 1.0
11 N. OF HNW-4-038		3.1 10.0	11 N. OF HNW-4-038		1.0 1.0
9 N. OF HNW-4-039		1.5 100.0	9 N. OF HNW-4-039		1.0 1.0
CLEAN D. I. WATER SAMPLE FROM 200 GAL. TANK		0.6 1.0		0.7 1.0	