



DBB	
Diagnostic breadboard:	DBID 0308, lock mode (4)
Selected laser beam:	35W laser (DBB shutter open)

POWER NOISE	
Measurement:	60 s = 1.0 min, 22. Aug 2012 15:36 PDT
Average DC signal:	9.343 V
DC signal range:	9.328 V . . 9.356 V (65536 Hz samplingrate)
Minimum power:	-0.16% ( [min-avg]/avg )
Relative peak-to-peak:	0.29% ( [max-min]/avg )
Photo current:	47 mA
Relative shot noise level:	2.62e-09 Hz <sup>-1/2</sup>

D A Q

Measurement duration:	60 s = 1.0 min
Measurement start:	22. Aug 2012 15:36 PDT (22. Aug 2012 22:36 UTC, 1029710196 GPS)
NDS:	h1nds1:8088 (v12r0)
User:	psl@operator2
Channels:	H1:PSL-DBB_RPD_DC_OUT 65536 Hz, H1:PSL-DBB_RPD_REL_PWR_OUT 65536 Hz, H1:PSL-DBB_SHUTTER 16 Hz, H1:PSL-DBB_DBID 16 Hz, H1:PSL-DBB_MON_SHUTTER_CLOSED 16 Hz, H1:PSL-DBB_MODE_NUM 16 Hz
Raw data:	<a href="#">rawdata.zip</a> (attached to this .pdf file, use Adobe Reader)
Calibration:	default.cali (embedded), 01. Jan 1970 00:00 UTC
Report source files:	<a href="#">report.zip</a> (attached to this .pdf file, use Adobe Reader)
Program:	dbb_rpn.py v0.6, Patrick Kwee, patrick.kwee@aei.mpg.de

I N F O

Measurement method: The power fluctuations of the beam were measured with a photodetector on the DBB. Detailed information about the measurement method and instructions for performing this measurement are available in Kwee et al., Appl. Opt., 47(32):6022–6032, 2008; LIGO-T0900133; LIGO-T0900579.
<i>no comment</i>