



| DBB | |
|------------------------------|---|
| Diagnostic breadboard: | DBID 0308, lock mode (4) |
| Selected laser beam: | 200W laser (DBB shutter open) |
| Power in DBB (RPD.DC): | 9.8 V |
| PMC resonant: | 100% |
| Beam alignment: | auto-alignment on |
| Modematching lens positions: | lens 1 (ML ₁) = -2.0 mm, lens 2 (ML ₂) = 4.8 mm, lenses not latched |

| POINTING | |
|--------------------------------------|--|
| Measurement: | 60 s = 1.0 min, 14. Jun 2013 13:21 PDT 1x = 0.022 eps _{rms} , -0.097 ... 0.110 eps, |
| Error signal: | 1y = 0.041 eps _{rms} , -0.157 ... 0.174 eps, 2x = 0.029 eps _{rms} , -0.101 ... 0.112 eps, 2y = 0.032 eps _{rms} , -0.125 ... 0.106 eps |
| Error signal slope (1x, 1y, 2x, 2y): | 7.04e-05 eps/cts, 9.25e-05 eps/cts, 1.12e-04 eps/cts, 1.09e-04 eps/cts |
| Error signal calibration age: | 3.1 min, 2.2 min, 1.7 min, 0.9 min |
| Control signal: | 1x = 0.053 ± 0.006 eps, 1y = -0.764 ± 0.012 eps, 2x = -0.030 ± 0.024 eps, 2y = -0.578 ± 0.021 eps |

D A Q

| | |
|-----------------------|--|
| Measurement duration: | 60 s = 1.0 min |
| Measurement start: | 14. Jun 2013 13:21 PDT (14. Jun 2013 20:21 UTC, 1055276512 GPS) |
| NDS: | h1nds1:8088 (v12r0) |
| User: | psl@operator2 |
| Channels: | <p>H1:PSL-DBB_QPD_1DX_CAL_OUT 65536 Hz, H1:PSL-DBB_QPD_1DY_CAL_OUT 65536 Hz, H1:PSL-DBB_QPD_2DX_CAL_OUT 65536 Hz, H1:PSL-DBB_QPD_2DY_CAL_OUT 65536 Hz, H1:PSL-DBB_CTRL_CTRL1X_EPS_OUTPUT 16 Hz, H1:PSL-DBB_CTRL_CTRL1Y_EPS_OUTPUT 16 Hz, H1:PSL-DBB_CTRL_CTRL2X_EPS_OUTPUT 16 Hz, H1:PSL-DBB_CTRL_CTRL2Y_EPS_OUTPUT 16 Hz, H1:PSL-DBB_SHUTTER 16 Hz, H1:PSL-DBB_DBID 16 Hz, H1:PSL-DBB_MON_SHUTTER_CLOSED 16 Hz, H1:PSL-DBB_MODE_NUM 16 Hz, H1:PSL-DBB_RPD_DC_OUTPUT 16 Hz, H1:PSL-DBB_CTRL_DSWITCH_ON 16 Hz, H1:PSL-DBB_LENS1 16 Hz, H1:PSL-DBB_LENS2 16 Hz, H1:PSL-DBB_LENS_LATCH 16 Hz, H1:PSL-DBB_CTRL_RESONANT 16 Hz, H1:PSL-DBB_QPD_MCALI_AGE_1X 16 Hz, H1:PSL-DBB_QPD_MCALI_AGE_1Y 16 Hz, H1:PSL-DBB_QPD_MCALI_AGE_2X 16 Hz, H1:PSL-DBB_QPD_MCALI_AGE_2Y 16 Hz, H1:PSL-DBB_QPD_MCALI_FACTOR_1X 16 Hz, H1:PSL-DBB_QPD_MCALI_FACTOR_1Y 16 Hz, H1:PSL-DBB_QPD_MCALI_FACTOR_2X 16 Hz, H1:PSL-DBB_QPD_MCALI_FACTOR_2Y 16 Hz</p> |
| Raw data: | rawdata.zip (attached to this .pdf file, use Adobe Reader) |
| Calibration: | default.cali (embedded), 01. Jan 1970 00:00 UTC |
| Report source files: | report.zip (attached to this .pdf file, use Adobe Reader) |
| Program: | dbb_pnt.py v0.6, Patrick Kwee, patrick.kwee@aei.mpg.de |

I N F O

Measurement method: The beam pointing fluctuations are measured with the differential wavefront sensing method. The fundamental mode of the DBB PMC is used as beam pointing reference. Shift and tilt of the beam are normalized with the beam waist radius and the beam divergence angle.

Detailed information about the measurement method and instructions for performing this measurement are available in Kwee et al., Appl. Opt., 47(32):6022–6032, 2008; LIGO-T0900133; LIGO-T0900579.

no comment