

Laboratory Vacuum E

Checked boxes under temperature sensors ("T"s) indicate that they are used in HVAC control. We leave many of these checked where there are no sensors nearer to the vacuum enclosure.

Temperature sensors near the vacuum enclosure (mounted on cable trays) are the best sensors for controlling the temperature of the vacuum enclosure

LVEA Zone Average 67.28 °F
Zone 1A, 1B, 4 and 5 Average 67.27 °F

☐ AHU Manual Disable
 AHU Command
55 °F Supply Air Temperature
8,653 cfm Supply Airflow

- ☐ Lights ON Command
- ☐ Lights OFF Command

